


Storm Sewer Profile
146th Ave NW - 10 year Event



| | | | | | |
|----------------------|---------|---------|---------|---------|--------|
| Node ID: | CB26142 | CB26138 | CB26134 | CB26128 | J26180 |
| Rim (ft): | 874.52 | 876.16 | 871.87 | 869.22 | 864.00 |
| Invert (ft): | 865.68 | 863.96 | 862.12 | 860.77 | 859.00 |
| Min Pipe Cover (ft): | 0.00 | 0.00 | 8.25 | 0.00 | 1.00 |
| Max HGL (ft): | 865.68 | 864.61 | 862.81 | 861.99 | 860.03 |
| Link ID: | L26138 | L26134 | L26128 | L26127 | |
| Length (ft): | 199.09 | 176.50 | 97.50 | 130.00 | |
| Dia (in): | 15.00 | 18.00 | 18.00 | 27.00 | |
| Slope (ft/ft): | 0.0086 | 0.0104 | 0.0138 | 0.0121 | |
| Up Invert (ft): | 865.68 | 863.96 | 862.12 | 860.77 | |
| Dn Invert (ft): | 863.96 | 862.12 | 860.77 | 859.20 | |
| Max Q (cfs): | 0.00 | 4.00 | 5.41 | 15.23 | |
| Max Vel (ft/s): | 0.00 | 5.31 | 5.07 | 7.59 | |
| Max Depth (ft): | 0.33 | 0.66 | 0.94 | 1.12 | |